



TEST REPORT

DATE: 07-28-2023

Page 1 of 1

TEST NUMBER: 0299082

CLIENT	SuZhou Tuntex Fiber & Carpet Company
---------------	--------------------------------------

TEST METHOD CONDUCTED	Phillips Roll Chair
------------------------------	---------------------



DESCRIPTION OF TEST SAMPLE	
IDENTIFICATION	Nexlon Carpet Tile
CONSTRUCTION	Multi-Level Loop Pile
BACKING	Duraback

GENERAL PRINCIPLE

This test is designed to determine what effect the action of rolling traffic has on a particular flooring surface. The sample is subjected to the reciprocating action of a chair base which is loaded to 150 pounds total weight. The chair castors are set to cause a random cycling motion resulting in an oval shaped wear pattern. After a predetermined number of cycles, the test sample is given a numerical rating based on the general appearance, with particular attention to pile crushing and matting.

TEST RESULTS

NUMBER OF CYCLES	APPEARANCE RATING
20,000	3.0

APPROVED BY:

This report is provided for the exclusive use of the client to whom it is addressed. It may be used in its entirety to gain product acceptance from duly constituted authorities. This report applies only to those samples tested and is not necessarily indicative of apparently identical of similar products. This report, or the name of Professional Testing Laboratory Inc. shall not be used under any circumstance in advertising to the general public.